


Reviewing Agency: FIRE MARSHAL
Review Date: 3/7/22

Reviewed By: PAUL D BARNES

Project Name: 22 SITE 2 (Western Group, LLC)
Project Location: 245 Route 32 (Map 70 Lot 10)



Comments: 2hr Rating for Garage. Min 1hr RATED FIRE DOOR FROM GARAGE TO RESIDENCE. STEPPED CONSTRUCTION REQ 2hr FIRE SEPARATION FROM SLAB TO ROOF PERK. NO INDICATIONS OF SMOKE ALARMS/CO ALARMS. IDENTIFY HEATING SYSTEM. CONCERN ABOUT 1 WAY IN/ONE WAY OUT IFC SECT 503.1.2. REQUIRE NO PARKING SIGNS TO DETER IN STREET PARKING. ADD hydrant MIDWAY DOWN DRIVEWAY

Electronic Signature:

A handwritten signature in black ink that appears to read "Paul Barnes". The signature is written in a cursive, flowing style.

LETTER OF TRANSMITTAL



Town of Montville Planning Department Date: January 28, 2022

310 Norwich New London Tpke

Uncasville, CT 06382

(860) 848-6779

Email: planningdept@montville-ct.org

- To: Town Engineer New London Water Building Dept. Assessor
- Town Attorney Norwich Water Fire Marshal Police
- Uncas Health Mayor DOT CAM
- WPCA Public Works DEEP Other

Project Name: 22 SITE 2 (Western Group, LLC)

Project Location: 245 Route 32 (Map 70 Lot 10)

The following have been transmitted:

- Application via Email Copy of Letter via Mail Plans via Email
- Regulations via Mail Other via Mail

Description
22 Unit Condominium Development

Transmitted as checked below. Your comments must be received on or before: 2/11/22

- For approval For your use As requested For your review and comment

Note: Comments are to be returned to mbadalucca@montville-ct.org

Remarks:

Signed: Meredith Badalucca
Meredith Badalucca, Admin. Asst.