

September 20, 2022

Liz Burdick
Planning Director Town of Montville
310 Norwich-New London Turnpike
Uncasville, CT 06382


Re: 1108 Old Colchester Road, 3-lot subdivision

Dear Ms. Burdick:

I have reviewed the revised plans for the above 3-Lot resubdivision and have the following comments:

1. An individual site plan must be submitted for each lot at the time of development.
2. The well on Lot 1 is less than the required 75 feet from sewer manhole 11.
3. The well on Lot 3 is less than the required 25 from the footing drain outlet.

Sincerely,

A handwritten signature in blue ink that reads "Michael J. Kirby". The signature is fluid and cursive, with a large loop at the end.

Michael J. Kirby, R.S.
Chief Environmental Sanitarian