

November 17, 2022

Liz Burdick
Planning Director Town of Montville
310 Norwich-New London Turnpike
Uncasville, CT 06382

Re: 22SUB 6- 137 Gay Hill Rd Subdivision

Dear Ms. Burdick,

I have reviewed the above subdivision plan and have the following comments:

1. Both lots meet the requirements for subsurface sewage disposal. Therefore, the District has no objection to the proposed subdivision.
2. The subsurface sewage disposal system for the proposed lot must be designed by a professional engineer.
3. Additional test holes will be required at the time the system is designed.

Sincerely,



Michael J. Kirby, R.S.
Chief Environmental Sanitarian