

From: [Michael Kirby](#)
To: ebartlett@greensitedesignllc.com
Cc: [Liz Burdick](#); [Colleen Bezanson](#)
Subject: 303, 307, & 309 route 32
Date: Monday, December 5, 2022 8:20:37 AM

CAUTION: This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Ellen,

This property is served by a well. The well is not located on the site plan. The application does not indicate if the buildings will be connected to the public water supply or continue to be served by the well. If they will be served by the well, the CT Department of Public Health, Drinking Water Section must be contacted to determine if the well will be classified as a public water system.

Mike

Michael J. Kirby, R.S.

Chief Environmental Sanitarian
860-823-1189 Extension 119

