

From: [Paul Barnes](#)
To: [Colleen Bezanson](#); [Dave Jensen](#)
Cc: [Liz Burdick](#)
Subject: RE: 23SITE1 689 Old Colchester Rd Accessory Office Building and Parking
Date: Friday, January 20, 2023 8:53:40 AM

Colleen,

I do not see any indication of emergency lights or exit signs. Also, no indication of a fire alarm system.

Paul D. Barnes, Sr.
Fire Marshal/ EMD
Town of Montville
