

**From:** [Paul Barnes](#)  
**To:** [Liz Burdick](#); [Meredith Badalucca](#)  
**Subject:** 305 Rte 32  
**Date:** Thursday, December 15, 2022 11:25:03 AM

---

Good morning,

In reference to our conversation this morning, the requirements for apartments has changed with the new Fire Code. All apartments will now be required to be sprinklered according to section 30.3.5 of the Life Safety Code regarding new apartments.

Any questions, please contact me.

Paul D. Barnes, Sr.  
Fire Marshal/ EMD  
Town of Montville