

**Project Name: Lombardi Gravel, LLC Multi-family units**  
**Project Location: 303 Route 32**

Reviewing Agency: Building Dept

Review Date: 2/14/23

Reviewed By: David Jensen

Notes:

The handicap parking space must be as close to the ramp as possible. Suggest moving the rear handicap space 3 spaces to the west/left.

Signature:

David M. Jensen