

February 23, 2023

Liz Burdick  
Planning Director Town of Montville  
310 Norwich-New London Turnpike  
Uncasville, CT 06382

Re: 689 Old Colchester Road, Breezeline

Dear Ms. Burdick:

I have reviewed the above plan revised February 13, 2023 and have the following comment:

1. Any utility trench backfilled with free-draining material, e.g. sand or gravel, must be a minimum of 25 feet from any part of the septic system.

Sincerely,



Michael J. Kirby, R.S.  
Chief Environmental Sanitarian