

**From:** [Michael Kirby](#)  
**To:** [Stacy Radford](#)  
**Cc:** [Liz Burdick](#)  
**Subject:** 486 Fitch Hill Road - Expansion of existing stable  
**Date:** Tuesday, June 13, 2023 2:21:17 PM  
**Attachments:** [image001.jpg](#)

---

**CAUTION:** This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

I have reviewed the above plan and have the following comments:

1. All existing wells and septic systems are to be noted on the plan.
2. A bathroom is proposed in the addition. There is no subsurface sewage disposal system or water supply indicated.
3. Deep test holes and a percolation test are required for a subsurface sewage disposal system.

*Michael J. Kirby, R.S.*  
Chief Environmental Sanitarian  
860-823-1189 Extension 119

