

LOT 3 - CULVERT DESIGN
 PINE GROVE SUBDIVISION
 OLD COLCHESTER ROAD
 MONTVILLE, CONN.

(SEE ATTACHED DRAINAGE AREA MAP)

AREA = 3.4 AC.

0.25 AC @ 0.9 (BIT/ROOF)

1.00 AC @ 0.35 (LAWN)

2.15 AC @ 0.25 (WOODS)

TOT A.C. = 1.1

$T_c \rightarrow 455'$ @ 8.0% - WOODED


$T_c = 18$ MIN

$Q = C_i A \rightarrow 25$ YR DESIGN


$Q = (1.1)(4.4 \text{ IN/HR}) = 4.8 \text{ CFS}$

$Q_{\text{MAX}} 15'' \text{ CULVERT} = 5.9 \text{ CFS} \checkmark$

USE FLARED ENDS @ INLET & OUTLET
 W/ MOD RIP RAP APRONS.



KEY MAP
SCALE : 1"=1000'





APPROVED
MONTVILLE PLANNING & ZONING COMMISSION

CHAIRMAN/SECRETARY _____	DATE _____
CHAIRMAN, INLAND WETLANDS AND WATERCOURSE COMMISSION _____	DATE _____
HEALTH DISTRICT _____	DATE _____

LEGEND

PROPOSED IRON PIN	
WETLAND UPLAND REVIEW LIMIT	
PROPERTY LINE	
BUILDING SETBACK LINE	
STONEWALL	
FENCE	
EXISTING CONTOUR	
NRCS SOIL SURVEY BOUNDARY	



I HEREBY DECLARE TO THE BEST OF MY KNOWLEDGE AND BELIEF THAT THIS PLAN IS SUBSTANTIALLY CORRECT.

Wesley J. Wentworth
WESLEY J. WENTWORTH P.E. # 20360

WENTWORTH CIVIL ENGINEERS LLC
177 WEST TOWN ST.
LEBANON, CT 06249
TEL: (860) 642-7255
FAX: (860) 642-4794
web: wentworthcivil.com

DRAINAGE PLAN - PROPOSED CULVERT
PINE GROVE SUBDIVISION
 PREPARED FOR
D'AMATO BROTHERS BUILDERS
 OLD COLCHESTER ROAD
 MONTVILLE, CONNECTICUT

DATE: 11-16-22
SCALE: 1"=100'
SHEET 4 OF 8
MAP NO. 22-013-10C