

**From:** [Paul Barnes](#)  
**To:** [Meredith Badalucca](#)  
**Subject:** 245 Rte 32  
**Date:** Tuesday, January 16, 2024 3:39:24 PM

---

Meredith,

I received the current plans for 245 Rte 32. These plans are listed as "Condominium" plans. The Fire Code does not recognize condominiums. They are either Multi-family or Townhouses. These proposed plans shall include a full sprinkler system and fire alarm per the Connecticut State Fire Safety Code.

Thank you

**PAUL D. BARNES SR.**  
**FIRE MARSHAL/EMD**  
**TOWN OF MONTVILLE**