

Megan Egbert

From: Michael Kirby <chfsanit@uncashd.org>
Sent: Tuesday, June 18, 2024 2:37 PM
To: Megan Egbert
Cc: Wes Wentworth
Subject: RE: 24 SUB 2 - Black Ash Estates

CAUTION: This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good afternoon,

1. Additional test holes were dug on lots 5,6,7 and 9, and those lots meet the minimum requirements for subsurface sewage disposal.
2. The septic calculations and system design have not been revised for Lot 11 to show the required 787.5 square feet.

From: Megan Egbert <megbert@montville-ct.org>
Sent: Wednesday, June 12, 2024 12:36 PM
To: Meredith Badalucca <mbadalucca@montville-ct.org>
Cc: Matthew Davis <mdavis@montville-ct.org>; Stacy Radford <sradford@montville-ct.org>; Michael Kirby <chfsanit@uncashd.org>; John Carlson <JCarlson@montville-ct.org>; dcolter@seccog.org; Doug Colter <dcolter@montville-ct.org>; Paul Barnes <pbarnes@montville-ct.org>; John Meigel <JMeigel@montville-ct.org>; khaubert@claengineers.com
Subject: RE: 24 SUB 2 - Black Ash Estates

Good Afternoon,

Below please find the link to access additional materials and revisions for the proposed 13-Lot Resubdivision at 970 Old Colchester Road (Black Ash Estates):

<https://link.edgepilot.com/s/7c7e2c1b/ZVt5craWS06ZFbkJc99Hcg?u=https://www.townofmontville.org/form-repository/24-sub-2-black-ash-estates/>

Please review the new documents and forward any comments to my attention at your earliest convenience.

Thank you,

Megan Egbert
Administrative Assistant
Land Use and Development
Town of Montville
310 Norwich New London Tpke
Uncasville, CT 06382
860.848.6779

From: Megan Egbert <megbert@montville-ct.org>
Sent: Monday, April 1, 2024 10:19 AM
To: Meredith Badalucca <mbadalucca@montville-ct.org>