

Megan Egbert

From: Megan Egbert
Sent: Monday, January 6, 2025 1:57 PM
To: Linda Acampora
Cc: Meredith Badalucca
Subject: FW: 24 SITE 12 - 25 Church Ln

Good Afternoon,

Please see below from the Fire Marshal's Office.

Thanks,
Megan

From: John Meigel <jmeigel@montville-ct.org>
Sent: Monday, January 6, 2025 11:26 AM
To: Douglas Colter <dcolter@seccog.org>; Meredith Badalucca <mbadalucca@montville-ct.org>; Paul Barnes <pbarnes@montville-ct.org>; Doug Colter <dcolter@montville-ct.org>
Cc: Megan Egbert <megbert@montville-ct.org>; Stacy Radford <sradford@montville-ct.org>
Subject: Re: 24 SITE 12 - 25 Church Ln

Meredith,

According to the IFC the emergency road access must be no less that 20 feet wide.

503.2.1 Dimensions

Fire apparatus access roads shall have an unobstructed width of not less than 20 feet (6096 mm), exclusive of shoulders, except for approved security gates in accordance with Section 503.6, and an unobstructed vertical clearance of not less than 13 feet 6 inches (4115 mm).

John Meigel
Deputy Fire Marshal
Town of Montville
Fire Services & Emergency Management
310 Norwich- New London Tpke
Uncasville, CT 06382
Phone: (860) 848-6781
Fax: (860) 848-4063
Office# 860-848-6729
Email : JMeigel@montville-ct.org

From: Megan Egbert <megbert@montville-ct.org>
Sent: Monday, December 30, 2024 3:52 PM
To: Meredith Badalucca <mbadalucca@montville-ct.org>